Directions For Use



Always align Locator to V-Groove before inserting adaptors/accessories.



Insert plug and turn clockwise to engage power.



Connect the USB charging cable (not included) to the charging port to begin charging your device.




GENESIS TRACK

User Guide



⚠ PLEASE READ BEFORE USE



250 V a.c. Single-phase : 13 Amp max. (1.5mm² 3-core cable) Rated Current (for pre-wired) 16 Amp max. (2.5mm² 3-core cable) 50Hz / 60Hz Rated Impulse Withstand Voltage : 4000V a.c. Track Material Aluminium Insulation Material Polycarbonate Dimension (Height x Depth) : 656mm x 99 x 25.4mm (refer to front side) Weight : Estimated 1.4kg Single USB Port Version No. of USB charging ports : 1 port Total Output : 5V / 2.1A : 1 x 2.0A (2.0A max.) Usage Scenario **Dual USB Port Version** No. of USB charging ports : 2 ports : 5V / 2.1A Total Output Usage Scenario : A - 2 x 1.0A (2.0A max.)

B - 1 x 2.0A (2.0A max.)

C - 1 x 1.0A (1.0A max.)

Technical Specifications

Eubiq Pte Ltd ("Eubiq") warrants to the end-user of the product ("the Customer") that the product will be free from defects in materials and workmanship under normal use for a period of three (3) years from the date of retail purchase by the original end-user purchaser ("Warranty Period"). The Customer should access and refer to Eubiq website at www.eubiq.com for

3 Years Limited Warranty

a list of Eubiq authorised dealers to contact for warranty service.

3. All requests for warranty service must be made within the Warranty Period, and be accompanied by the original dated proof of purchase.


ALL RIGHTS RESERVED.
EUBIQ AND GSS ARE THE REGISTERED TRADEMARKS OF EUBIQ PTE LTD.


K-005-030-01

Surface-Mount Installation




Mark locations of mounting brackets. Use a level tool if necessary. Then, remove brackets from GT1.0 Track.





Drill holes for mounting screws with Ø4mm




Secure brackets to the wall with the screws




Attach GT1.0 Track to the mounting brackets. GT1.0 is now ready for use.


Semi-Recess Installation (Wall/Table)




Prepare cutout opening for GT1.0 Track. [541 * 68mm] Remove the brackets from GT1.0 Track.




Drill holes for mounting screws with Ø4mm drill bit.



Attach GT1.0 Track to the mounting brackets. GT1.0 is now ready for use.



Mark locations for drilled holes.



Secure brackets to the wall/table surface with the screws provided.